

Fort Lewis Annual Water Quality Report

July 2003

CONTENTS

- ❖ Monitoring and Treatment
- ❖ How We Ensure Safe Drinking Water
- ❖ Drinking Water Sources
- ❖ Sources of Constituents
- ❖ Microbial Testing
- ❖ Chlorine Residual
- ❖ Lead, Copper, Arsenic, Analyses
- ❖ Special Concerns
- ❖ Water Quality Results
- ❖ Important Definitions
- ❖ Frequently Asked Questions

Drinking Water Sources

Fort Lewis operates three public water systems, all of which rely entirely on groundwater. Groundwater is an excellent source of drinking water because of the natural filtration process that takes place. The main system supplies water to over 30,000 people in the cantonment area on Fort Lewis. The primary source is Sequelitchew Springs. Nine other wells around the post are available for use during peak demand periods. These sources produced about 1.7 billion gallons of clean water last year.

The other two systems include the Golf Course and the Ammunition Supply Point, each being served by a single well. ☺

Water Quality Monitoring

The Fort Lewis Public Works is pleased to provide you with the 2003 Annual Water Quality Report. This report provides a snapshot of the quality of water we provided during 2002, a description of where our water comes from, a list of potential sources of contamination, and how we ensure that our water is safe to drink. This publication conforms to the provision in the Safe Drinking Water Act (SDWA), requiring water utilities to provide this information annually. We are proud to report that our water meets all Federal and State drinking water standards. The information in this report is also submitted to the Washington State Department of Health. ☺



How Public Works Ensures Safe Drinking Water for Fort Lewis

Fort Lewis Public Works closely monitors our drinking water by collecting over 500 water samples per year which are analyzed by a state certified laboratory to look for over 300 possible contaminants. This includes 40 bacteriological samples a month, ensuring that our treatment plant provides the highest quality of water possible. These results are distributed to various federal and state agencies. The water plant also adds chlorine, fluoride, and polyphosphate to the water prior to entering the distribution system to ensure safe, bacteria free water. In addition to these quality control checks and treatment procedures, the Fort Lewis water system has a Backflow Prevention Program, designed to prevent contaminants from entering drinking water via cross-connections between the public water system and non-potable water sources. These back-flow assemblies are inspected regularly to ensure they are working properly. **The bottom line is that our water is safe to drink.**

In the event a water sample is over a threshold for safe drinking water levels, Fort Lewis Public Works would shut down the system and notify all consumers. The contaminant source would be identified and the problem fixed. When safe drinking water is restored, consumers would be notified and informed of the cause of the problem. ☺

Sources of Fort Lewis' Water Constituents

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. As water travels over the land's surface and through the ground, it dissolves naturally occurring minerals (iron, manganese, lead), radioactive material, and can be polluted by animal waste and human activity. Contaminants that might be expected in untreated water include: *biological contaminants*, such as bacteria; *inorganic contaminants*, such as salts and metals; *pesticides and herbicides*; and *organic chemicals*, such as fuels and oils. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline at 1-800-426-4791. ☞

Microbiological Testing

Microbial pathogens such as *Giardia lamblia*, *Cryptosporidium* and *fecal coliform bacteria* are found predominantly in surface and standing waters. Because the Fort Lewis Water System relies solely on groundwater sources, the threat is greatly reduced. The disinfection treatment process (chlorine addition) used on Fort Lewis water is also very effective in eliminating residual organisms. With the treatment process and extensive microbiological testing and monitoring, Fort Lewis Public Works is able to protect the public from diseases caused by these organisms. The SDWA requires unfiltered water systems to meet strict standards for total and fecal coliform bacteria. Testing for these bacteria before and after disinfection helps confirm the effectiveness of the disinfection process. ☞

Chlorine Residual

The water treatment process involves the addition of chlorine to the water. This ensures the safe and continuous disinfection of the water while in the distribution system. The amount of chlorine in the water, the chlorine residual, is monitored to determine its effectiveness. The levels must be high enough to be effective in eliminating bacteria but not too high as to cause an undesirable taste. ☞

RESIDENTIAL LEAD/COPPER SAMPLING RESULTS

Analyte	Maximum Amount Detected	Maximum Contaminant Level (MCL)	Maximum Contaminant Level Goal (MCLG)	Source of Contaminant
Copper	90% of the homes tested had copper levels less than 0.41 ppm	90% of the homes tested must have copper levels less than 1.3 ppm	0 ppm	Corrosion of household plumbing
Lead	90% of the homes tested had lead levels less than 2 ppb	90% of the homes tested must have levels less than 15 ppb	0 ppb	

Lead, Copper, Arsenic

Lead and copper monitoring is conducted separately from other analyses and is an indirect measurement of the corrosivity of water relative to the materials in the distribution system. Fort Lewis was well under the initial federal requirements for lead and copper concentrations in the distribution system. Currently Public Works collects and analyzes 35 samples every three years. The reduction in monitoring is possible because of improvements to the water treatment facility operation, which lowered the acidity and reduced the corrosivity of the water.

All arsenic samples are under the recently lowered federal regulatory level (10ppb) for safe drinking water. ☞

Special Concerns

Some people may be at a higher risk from contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemo-therapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/Center for Disease Control and Prevention (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791). ☞

REGULATED CONSTITUENTS

Analyte	Max Amount Detected	Max Contaminant Level (MCL)	Max Contaminant Level Goal (MCLG)	Potential Source of Contaminant
Inorganic Metals				
Iron	200 ppb	300 ppb	<300 ppb	Natural Geology
Lead	13 ppb*	15 ppb	<15 ppb	
Manganese	110 ppb*	50 ppb	<50 ppb	
Arsenic	4 ppb	10 ppb	<10 ppb	
Inorganic Non-metals				
Chloride	4.7 ppm*	250 ppm	<250 ppm	Natural Geology
Conductivity	100 µmhos/cm	700 µmhos/cm	<50 µmhos/cm	
Color	20 CU**	15 CU	<15 CU	Additive
Fluoride	1.1 ppm*	2 ppm	<2 ppm	
Nitrate	1.4 ppm	10 ppm	<10 ppm	Runoff
Sulfate	10.2 ppm*	250 ppm	<250 ppm	Natural Geology
TDS	130 ppm*	500 ppm	<500 ppm	
Turbidity	0.3 NTU	1 NTU	<1 NTU	
Volatile Organic Compounds				
Dichloro-methane	0.7 ppb*	5.0 ppb	<200 ppb	Solvents
Chloroform	0.8 ppb	5.0 ppb	<5.0 ppb	
Tri-chloroethene	0.6 ppb*	5.0 ppb	<5.0 ppb	
Synthetic Organic Compounds				
Di-(ethylhexyl)-phthalate	2.8 ppb*	6.0 ppb	<6.0 ppb	Rubber and plastic Materials

ppm – parts per million

ppb – parts per billion

* Some of our data, though representative, are more than one year old (collected in either 2000 or 2001). The state allows us to monitor for some contaminants less than once per year because the concentration of these contaminants do not change frequently.

** One sample collected in 2001 exceeded the MCL for Color (CU). This is a secondary constituent primarily used to monitor suspended matter present and does not pose a health threat.

IMPORTANT DEFINITIONS

Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contamination.

Color Units (CU) - Color is a measurement that qualitatively relates the amount of dissolved materials plus and suspended matter present in a water sample.

Microhms per centimeter (µmhos/cm) - Conductivity is an index of the flow of electrical current in a substance; it is also an indirect measurement of dissolved solids in water.

Nephelometric Turbidity Units (NTU) - Turbidity is a measurement of water clarity.

Total Dissolved Solids (TDS) - TDS is a measurement of the amount of dissolved solids in a water sample.

MICROBIOLOGICAL ANALYSES BEFORE AND AFTER DISINFECTION

Analyte	Maximum Amount Detected	Maximum Contaminant Level (MCL)	Maximum Contaminant Level Goal (MCLG)	Potential Source of Contaminant
Microbiological Analysis at Your Tap				
Microbiological Contaminant Total Coliform Bacteria	Zero samples tested positive for Coliform bacteria.	Coliform bacteria may be present in no more than 5% of monthly samples.	Zero bacteria detected.	Regrowth of soil bacteria in the distribution system.
Disinfection Residual Chlorine Residual	All samples had detectable chlorine residual	Not regulated at this time.		Chlorine is used as a disinfectant in the water treatment process.
Microbiological Analysis Before Treatment				
Total Coliform Bacteria	100% of our samples had fewer than 40 bacteria per 100 milliliters of water.	90% of samples Must have fewer than 100 bacteria per 100 milliliters.	Zero bacteria detected	Soil bacteria and animal feces.
Fecal Coliform Bacteria	100% of our samples had fewer than 20 bacteria per 100 milliliters of water.	90% of samples Must have fewer than 20 bacteria per 100 milliliters.	Zero bacteria detected	Animal feces.

FREQUENTLY ASKED QUESTIONS

What are the potential health effects of contaminated water? Chronic (over a long period of time) exposure to contaminants is not likely, due to our extensive monitoring program. Acute (short period of time) exposure, such as the consumption of drinking water contaminated with cryptosporidium, often results in diarrhea, abdominal pain, vomiting, and low-grade fever, similar to food poisoning.

Does Fort Lewis add fluoride to the water? Yes, Fort Lewis does add fluoride to the water.

Why does the water sometimes taste like chlorine? Fort Lewis uses chlorine for disinfection before water enters the distribution system. Chlorine has been shown to be a safe and effective agent, and is used by most municipalities across the country. Sometimes, when the water has been sitting for some time in the pipe, some of the chlorine comes out of solution. When this happens, you may smell or even taste it; however, the water is still safe to drink.

Why does the water sometimes look rusty? Rusting of galvanized pipe in plumbing systems is the typical cause of discolored water. Iron causes the discoloration; it is not a health risk. If the water is discolored, run it until it becomes clear again.

Is the drinking water at Fort Lewis safe? All drinking water at Fort Lewis is safe. Public Works tests the water frequently for physical, chemical, and biological parameters, to ensure it meets or exceeds all drinking water quality standards. As an added precaution, potable water is disinfected before it enters the distribution system.

CUSTOMERS VIEWS WELCOME

This is important information, and we believe it is vital that it is readable and understandable. If you are interested in learning more about the water service and water quality on Fort Lewis or have any suggestions on how we could improve this report, please feel free to contact us. Questions about water quality can be answered by calling the Water Quality Technician at Fort Lewis Public Works at (253) 966-1772. ↪

This report can be viewed on the Fort Lewis intranet at:

<http://www.lewis.army.mil/waterreport/2002CCR.pdf>

Fort Lewis Public Works
Environmental & Natural Resources Division
Water Quality Office
AFZH-PWE MS-17 BLDG 2012
Fort Lewis, WA 98433-9500

General
Distribution
Fort Lewis
WA

FORT LEWIS DRINKING WATER
CUSTOMER

WHERE TO GO FOR MORE INFORMATION

Washington State Department of Health:
<http://www.doh.wa.gov/ehp/dw/default.htm>

Environmental Protection Agency (EPA):
<http://www.epa.gov>

EPA Safe Drinking Water Hotline: **800-426-4791**

